

VOC Content Test Certificate

Monday, 29th January 2018

Supplier: Soudal Pty Ltd Australia (1 Tollis Place, Seven Hills, NSW 2147).

Sample Description: Fill & Paint Flexible Gap Filler

Date Tested: January 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|--|---|
| Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B | Fill & Paint Flexible Gap Filler |
| General purpose adhesives and sealants: 50 grams per Litre as VOC content per material | 24 grams per Litre as VOC content per material |
| <p><i>We hereby certify Fill & Paint Flexible Gap Filler is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV171250