

## FINAL REPORT

Report ID : 162901

### Report Information

**Submitting Organisation :** 00121668 : Soudal Australia

**Account :** 142619 : Soudal Australia

**AWQC Reference :** 142619-2015-CSR-3 : Soudal Roof & Gutter Clear/Trans 300 ML (Microbial Growth Onl

**Project Reference :** PT-2655

**Product Designation :** Soudal Roof & Gutter Silicone Clear/Trans 300mL (127779)

**Composition of Product :** Neutral Cure Silicone.

**Product Manufacturer :** Soudal, BELGIUM.

**Use of Product :** In-Line/Silicone Sealant.

**Sample Selection:** As provided by the submitting organisation.

**Testing Requested :** **AS/NZS 4020:2005 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**

**Product Type :** Composite

**Samples :** Samples were prepared and controlled as described in Appendix A of AS/NZS 4020: 2005

**Extracts :** Extracts were prepared as described in Appendix E.

**Project Completion Date :** 10-Sep-2015

**Project Comment :** The results presented herein demonstrate compliance of the Soudal Roof & Gutter Silicone Clear/Trans 300mL (127779) to Appendix E - Growth of Aquatic Microorganisms only when exposed at area to volume ratios up to 2100 mm<sup>2</sup>/L.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Michael Glasson  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance with ISO/IEC 17025